



Heilbrigðiseftirlit Vestfjarða  
5912881219  
Vitastíg 1  
Bolungarvík

Sample No. R24010150002  
Water

Sample Date: 13/05/2024  
Received: 14/05/2024  
Analysed: 14/05/2024

Sample Type : Drinking water  
Sample Location : Patreksfjörður, Vesturbyggð  
Sample Reference : 2-Patró/Port of Patreksfjörður  
Other information :  
Comments : Sample fulfils Icelandic drinking water regulation no. 536/2001

Microbiological Analysis	Result	Reference
E.coli in 100 ml MF (ÖVA3)	<1	ISO 9308-1:1990 & ISO 9308-1:2000
Total count in 1 ml at 22°C (ÖVA5)	13	SM, 23. ed.2017, 9215B & ISO 6222:1999 mod.
Coliforms in 100 ml (ÖVA3) MF	<1	ISO 9308-1:1990 & ISO 9308-1:2000

Reykjavík,

21.5.2024

This laboratory report is approved  
and digitally signed:

Matthew Hiller  
matthew.hiller@matis.is

The results apply only to the material that has been identified, received, and tested. Analysis was performed on samples as received. Laboratories are accredited by the Swedish Board for Accreditation and Conformity Assessment (SWEDAC) under the terms of Swedish legislation. The accredited laboratory activities meet the requirements of the ISO/IEC 17025 standard. This test report/certificate may only be reproduced in whole, otherwise a written permission from Matís is required. The laboratory meets the demands of the NELAC standard of New York State Department of Health (NYSDOH), NY Lab Id No: 11290. Information about uncertainty of the analysis can be sought upon request by contacting the laboratory. For further information, please contact the person signing the report or Hrólfur Sigurðsson project manager.